

LAMPIRAN 1

Data Hasil Pengukuran Intensitas Pencahayaan

Ruang Pamer 01

Lokasi/Titik	Hasil Pengukuran (lux)			Rata-Rata
	I	II	III	
Titik 1	112	110	113	111,66
Titik 2	155	152	155	154
Titik 3	152	150	155	152,33
Titik 4	114	110	114	112,66
Titik 5	147	150	149	148,66
Titik 6	89	87	90	88,66
Titik 7	134	135	135	134,67
Titik 8	141	140	141	140,67
Titik 9	100	101	100	100,33
Titik 10	90	92	93	91,67
Titik 11	70	72	70	70,67
Titik 12	100	100	100	100
Rata-rata intensitas pencahayaan				117,165

Ruang Pamer 02

Lokasi/Titik	Hasil Pengukuran (lux)			Rata-Rata
	I	II	III	
Titik 1	123	124	120	122,33
Titik 2	86	85	80	83,67
Titik 3	120	117	118	118,33
Titik 4	120	115	120	118,33
Titik 5	134	135	135	134,67
Titik 6	130	130	132	130,67
Titik 7	154	154	156	154,67
Rata-rata intensitas pencahayaan				123,24

Ruang Pamer 03

Lokasi/Titik	Hasil Pengukuran (lux)			Rata-Rata
	I	II	III	
Titik 1	158	159	159	158,67
Titik 2	187	185	185	185,67
Titik 3	190	192	193	191,67
Titik 4	225	228	227	226,67

Titik 5	225	220	225	223,33
Titik 6	200	200	202	200,67
Titik 7	200	203	201	201,33
Titik 8	172	170	170	170,67
Titik 9	186	186	185	185,67
Titik 10	176	176	177	176,33
Titik 11	163	160	165	162,67
Titik 12	188	185	184	185,67
Titik 13	156	157	156	156,33
Titik 14	105	104	104	104,67
Titik 15	78	78	80	78,67
Titik 16	48	45	48	47
Titik 17	75	75	70	73,33
Titik 18	124	124	125	124,33
Titik 19	120	120	119	119,67
Titik 20	89	90	90	89,67
Titik 21	66	70	70	68,67

Titik 22	28	30	28	28,67
Titik 23	49	50	48	49
Titik 24	70	68	68	68,67
Titik 25	233	230	230	231
Rata-rata intensitas pencahayaan				140,35

Ruang Pamer 04

Lokasi/Titik	Hasil Pengukuran (lux)			Rata-Rata
	I	II	III	
Titik 1	105	104	105	104,67
Titik 2	79	78	79	78,67
Titik 3	60	62	60	60,67
Titik 4	42	42	43	226,67
Titik 5	106	105	105	42,33
Titik 6	128	128	125	105,33
Titik 7	145	147	147	127
Titik 8	80	85	85	146,33
Titik 9	135	139	135	136,33

Titik 10	140	140	137	139
Titik 11	113	110	115	112,67
Titik 12	32	34	30	32
Titik 13	196	192	196	194,67
Titik 14	180	178	180	179,33
Titik 15	156	156	155	155,67
Titik 16	90	88	90	89,33
Titik 17	213	214	210	212,33
Titik 18	229	229	227	228,33
Titik 19	219	215	220	218
Titik 20	163	164	165	164
Titik 21	167	165	160	164
Titik 22	198	199	195	197,33
Titik 23	196	198	199	197,67
Titik 24	180	185	185	183,33
Titik 25	165	166	166	165,67
Rata-rata intensitas pencahayaan				140,72

Ruang Pamer 05

Lokasi/Titik	Hasil Pengukuran (lux)			Rata-Rata
	I	II	III	
Titik 1	45	45	46	45
Titik 2	39	40	39	39,33
Titik 3	68	68	69	68,33
Titik 4	45	46	45	45,33
Titik 5	90	91	92	91
Titik 6	163	160	163	162
Titik 7	44	42	43	43
Titik 8	47	46	47	46,67
Titik 9	77	76	77	76,67
Titik 10	58	58	59	58,33
Titik 11	92	90	91	91
Titik 12	101	102	101	101,33
Titik 13	50	50	51	50,33
Titik 14	50	50	51	50,33
Titik 15	58	57	56	57

Titik 16	48	49	50	49
Titik 17	98	97	98	97,67
Titik 18	123	122	123	122,67
Titik 19	50	51	51	50,67
Titik 20	48	49	48	48,33
Titik 21	49	50	49	49,33
Titik 22	40	41	40	40,33
Titik 23	97	96	95	96
Titik 24	72	72	73	72,33
Titik 25	39	38	39	38,67
Rata-rata intensitas pencahayaan				67,63

Ruang Pamer 06

Lokasi/Titik	Hasil Pengukuran (lux)			Rata-Rata
	I	II	III	
Titik 1	136	131	136	134,33
Titik 2	136	115	118	123
Titik 3	154	149	154	152,33

Titik 4	176	176	175	175,67
Titik 5	140	138	140	139,33
Titik 6	201	202	201	201,33
Titik 7	194	195	196	195
Titik 8	193	190	190	192
Rata-rata intensitas pencahayaan				164,12



LAMPIRAN 2

DOKUMENTASI

Pengukuran Pencahayaan



Simulasi DIALux Evo

