

Konlis tanggal 31 Januari 2017

Periode II	KONDISI KELISTRIKAN	
	17.00 - 22.00 DM (KW)	BP (KW)
Total Sistem Bangka	164,706	118,172
Surplus/Defisit	46,534	-
Total Sistem Interkoneksi	139,700	96,300
Surplus/Defisit	43,400	-
PLTU Unit 1	-	-
PLTU Unit 2	13,000	12,600
MPP #1	25,000	19,000
MPP #2	25,000	18,000
PLTD Merawang	26,300	18,900
PLTU Listrindo	3,400	3,400
Sewatama	22,000	6,700
Kertabumi I	20,000	13,900
Kertabumi II	5,000	3,800
Sub Sistem Koba - Toboali	16,950	16,600
Surplus/Defisit	350	-
PLTD Toboali	8,900	8,750
PLTD Koba	8,050	7,850
Total Sistem Isolated	25,006	21,872
Surplus/Defisit	3,134	-
PLTD Mentok	7,800	5,147
PLTD Jebus	-	-
Pongok	128	70
Celagen	128	55

Konlis tanggal 31 Maret 2017

ARUS PER PENYULANG BEBAN PUNCAK MALAM PUKUL 19.00 WIB							
Penyulang	Pembangkit/GI	R	S	T	Arus rata-rata		Beban (kW)
Berok (KB1)		39	37	38	38	38	1,118
Nibung(KB2)		64	65	64	64	64	1,892
Terentang (KB3)	PLTD KOBA	39	39	37	38	38	1,127
Dara(KB4)		95	93	98	95	95	2,804
Beriga (KB5)		34	35	35	35	34	1,020
Kulur (KB6)	GI KOBA	43	42	42	42	42	1,245
Padang Mulia (KB7)		22	22	22	22	22	647
INC PLTD 1		55	55	55	55	55	1,618
Palas (PY 1)		54	52	53	53	53	1,559
Paku (PY 2)		84	84	88	85	85	2,510
Kota (TB1)	TOBOALI	93	96	96	95	95	2,794
Rindik (TB2)		31	33	33	32	32	951
Bikang (TB3)		14	15	14	14	14	422
Sadai (TB4)		72	70	71	71	71	2,088
Suka damai (TB5)		32	31	33	32	32	941

		DIGSI1887 PowerFactory 14.1.3	Project: Date: 7/24/2017
--	--	-------------------------------------	-----------------------------

Load Flow Calculation	Complete System Report: Voltage Profiles, Grid Interchange		
AC Load Flow, balanced, positive sequence	No	Automatic Model Adaptation for Convergence	No
Automatic Tap Adjust of Transformers	No	Max. Acceptable Load Flow Error for	1.00 kVA
Consider Reactive Power Limits	No	Model Equations	0.10 %

Grid: singlelinediagram	System Stage: singlelinediagr	Study Case: Study Case	Annex: / 1
-------------------------	-------------------------------	------------------------	------------

	rtd.V [kV]	Bus - voltage		Voltage - Deviation [%]					
		[p.u.]	[kV]	[deg]	-10	-5	0	+5	+10
Terminal (1)	20.00	0.972	19.44	-1.11					
Terminal (2)	20.00	0.934	18.68	-1.89					
Terminal (3)	20.00	0.969	19.38	-1.17					
Terminal (5)	20.00	0.983	19.66	-0.90					
Terminal (7)	20.00	0.983	19.66	-0.90					
Terminal (8)	20.00	0.981	19.61	-0.94					
Terminal (9)	20.00	0.977	19.55	-1.01					
Terminal (13)	20.00	0.970	19.41	-0.63					
Terminal (14)	20.00	0.970	19.39	-0.64					
Terminal (16)	20.00	0.981	19.62	0.53					
Tobosli	20.00	0.985	19.70	-0.86					
TJ Labu	20.00	0.929	18.57	-2.00					
Suka Damai	20.00	0.982	19.63	-0.92					
Tangit	20.00	0.976	19.51	-1.04					
Kepoh	20.00	0.967	19.34	-1.22					
Nangka-KP Jawa	20.00	0.968	19.36	-0.46					

Grid: singlelinediagram	System Stage: singlelinediagr	Study Case: Study Case	Annex: / 2						
	rtd.V [kV]	Bus - voltage [p.u.]	[kV] [deg]	-10	-5	Voltage - Deviation [%]	0	+5	+10
Air Sara-Nangk	20.00	0.968	19.37	-0.33					
koba	20.00	0.991	19.83	0.98					
PLTD Toboali	6.30	1.000	6.30	0.00					
terminal	20.00	1.037	20.74	2.79					
PLTD Koba	6.30	1.000	6.30	1.77					
GI Koba	150.00	1.000	150.00	4.30					



		DIGSILENT PowerFactory 14.1.3	Project: Date: 7/24/2017
--	--	-------------------------------------	-----------------------------

Load Flow Calculation	Complete System Report: Voltage Profiles, Grid Interchange
-----------------------	--

AC Load Flow, balanced, positive sequence	No	Automatic Model Adaptation for Convergence	No
Automatic Tap Adjust of Transformers	No	Max. Acceptable Load Flow Error for Nodes	1.00 kVA
Consider Reactive Power Limits	No	Model Equations	0.10 %

Grid: singlelinediagram	System Stage: singlelinediagr	Study Case: Study Case	Annex: / 3
-------------------------	-------------------------------	------------------------	------------

Volt. Level [kV]	Generation [MW]/[Mvar]	Motor Load [MW]/[Mvar]	Load [MW]/[Mvar]	Compensation [MW]/[Mvar]	External Infeed [MW]/[Mvar]	Interchange to	Power Interchange [MW]/[Mvar]	Total Losses [MW]/[Mvar]	Load Losses [MW]/[Mvar]	No-load Losses [MW]/[Mvar]
6.30	13.97 9.81	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00			0.00 0.00	0.00 0.00	0.00 0.00
						20.00 kV	13.97 9.81	0.03 0.32	0.03 0.32	0.00 0.00
20.00	0.00 0.00	0.00 0.00	20.71 12.83	0.00 0.00	0.00 0.00			0.22 0.27	0.22 0.27	0.00 0.00
						6.30 kV	-13.94 -9.48	0.03 0.32	0.03 0.32	0.00 0.00
						150.00 kV	-6.99 -3.63	0.01 0.24	0.01 0.24	0.00 0.00
150.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	7.00 3.87			0.00 0.00	0.00 0.00	0.00 0.00
						20.00 kV	7.00 3.87	0.01 0.24	0.01 0.24	0.00 0.00
Total:	13.97 9.81	0.00 0.00	20.71 12.83	0.00 0.00	7.00 3.87		0.00 0.00	0.26 0.84	0.26 0.84	0.00 0.00

		DigSILENT PowerFactory 14.1.3	Project: Date: 7/24/2017
--	--	-------------------------------------	-----------------------------

Load Flow Calculation		Complete System Report: Voltage Profiles, Grid Interchange	
AC Load Flow, balanced, positive sequence	No	Automatic Model Adaptation for Convergence	No
Automatic Tap Adjust of Transformers	No	Max. Acceptable Load Flow Error for	
Consider Reactive Power Limits	No	Nodes	1.00 kVA
		Model Equations	0.10 %

Total System Summary					Study Case: Study Case	Annex:	/ 4	
Generation	Motor Load	Load	Compensation	External Infeed	Inter Area Flow	Total Losses	Load Losses	No-load Losses
[MW]/ [Mvar]	[MW]/ [Mvar]	[MW]/ [Mvar]	[MW]/ [Mvar]	[MW]/ [Mvar]	[MW]/ [Mvar]	[MW]/ [Mvar]	[MW]/ [Mvar]	[MW]/ [Mvar]
\Andry Yuliansyah\skripsi\Network Model\Network Data\singlelinediagram								
13.97	0.00	20.71	0.00	7.00	0.00	0.26	0.26	0.00
9.81	0.00	12.83	0.00	3.87	0.00	0.84	0.84	0.00
Total:								
13.97	0.00	20.71	0.00	7.00		0.26	0.26	0.00
9.81	0.00	12.83	0.00	3.87		0.84	0.84	0.00


		DigSILENT PowerFactory 14.1.3	Project: Date: 1/24/2017
--	--	-------------------------------------	-----------------------------

Load Flow Calculation	Complete System Report: Voltage Profiles, Grid Interchange		
AC Load Flow, balanced, positive sequence	No	Automatic Model Adaptation for Convergence	No
Automatic Tap Adjust of Transformers	No	Max. Acceptable Load Flow Error for Nodes	1.00 kVA
Consider Reactive Power Limits	No	Model Equations	0.10 %

Grid: singlelinediagram	System Stage: singlelinediagr	Study Case: Study Case	Annex: / 1
-------------------------	-------------------------------	------------------------	------------

	rtd.V [kV]	Bus - voltage [p.u.]	[kV]	[deg]	-10	-5	Voltage - Deviation [%] 0	+5	+10
Terminal(1)	20.00	0.977	19.55	-1.04					
Terminal(2)	20.00	0.962	19.23	-1.48					
Terminal(3)	20.00	0.974	19.49	-1.10					
Terminal(5)	20.00	0.983	19.66	-0.90					
Terminal(7)	20.00	0.983	19.66	-0.89					
Terminal(8)	20.00	0.981	19.61	-0.94					
Terminal(9)	20.00	0.978	19.55	-1.00					
Terminal(13)	20.00	0.970	19.41	-0.62					
Terminal(14)	20.00	0.970	19.39	-0.63					
Terminal(16)	20.00	0.981	19.62	0.53					
Toboali	20.00	0.985	19.70	-0.85					
TJ Labu	20.00	0.957	19.13	-1.59					
Suka Damai	20.00	0.982	19.64	-0.92					
Tangit	20.00	0.976	19.52	-1.04					
Kepoh	20.00	0.967	19.34	-1.21					
Mangka-KP Jawa	20.00	0.968	19.36	-0.46					

Grid: singlelinediagram	System Stage: singlelinediagr	Study Case: Study Case	Annex: / 2	
	rtd.V [kV]	Bus - voltage [p.u.]	[kV] [deg]	Voltage - Deviation (%) -10 -5 0 +5 +10
Air Bers-Bangka	20.00	0.969	19.37 -0.32	
koba	20.00	0.991	19.83 0.99	
PLTD Toboali	6.30	1.000	6.30 0.00	
terminal	20.00	1.037	20.74 2.80	
PLTD Koba	6.30	1.000	6.30 1.78	
GI Koba	150.00	1.000	150.00 4.31	



		DIGSILENT PowerFactory 14.1.3	Project: Date: 7/24/2017
--	--	-------------------------------------	-----------------------------

Load Flow Calculation	Complete System Report: Voltage Profiles, Grid Interchange		
AC Load Flow, balanced, positive sequence		Automatic Model Adaptation for Convergence	No
Automatic Tap Adjust of Transformers	No	Max. Acceptable Load Flow Error for	
Consider Reactive Power Limits	No	Nodes	1.00 kVA
		Model Equations	0.10 %

Grid: singlelinediagram	System Stage: singlelinediagr	Study Case: Study Case	Annex:	/ 3						
Volt. Level [kV]	Generation [MW]/ [Mvar]	Motor Load [MW]/ [Mvar]	Load [MW]/ [Mvar]	Compensation [MW]/ [Mvar]	External Infeed [MW]/ [Mvar]	Interchange to	Power Interchange [MW]/ [Mvar]	Total Losses [MW]/ [Mvar]	Load Losses [MW]/ [Mvar]	NoLoad Losses [MW]/ [Mvar]
6.30	13.92 9.76	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	20.00 kV	13.92 9.76	0.00 0.03 0.32	0.00 0.03 0.32	0.00 0.00 0.00
20.00	0.00 0.00	0.00 0.00	20.71 12.83	0.00 0.00	0.00 0.00	6.30 kV 150.00 kV	-13.90 -9.44 -6.99 -3.62	0.18 0.23 0.03 0.32 0.01 0.24	0.18 0.23 0.03 0.32 0.01 0.24	0.00 0.00 0.00 0.00 0.00 0.00
150.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	7.00 3.86	20.00 kV	7.00 3.86	0.00 0.01 0.24	0.00 0.01 0.24	0.00 0.00 0.00
Total:	13.92 9.76	0.00 0.00	20.71 12.83	0.00 0.00	7.00 3.86		0.00 0.00	0.21 0.79	0.21 0.79	0.00 0.00

		DigSILENT PowerFactory 14.1.3	Project: Date: 7/24/2017
--	--	-------------------------------------	-----------------------------

Load Flow Calculation	Complete System Report: Voltage Profiles, Grid Interchange		
AC Load Flow, balanced, positive sequence		Automatic Model Adaptation for Convergence	No
Automatic Tap Adjust of Transformers	No	Max. Acceptable Load Flow Error for	
Consider Reactive Power Limits	No	Nodes	1.00 kVA
		Model Equations	0.10 %

Total System Summary		Study Case: Study Case			Annex:		/ 4	
Generation	Motor Load	Load	Compensation	External Infeed	Inter Area Flow	Total Losses	Load Losses	No-load Losses
[MW]/ [Mvar]	[MW]/ [Mvar]	[MW]/ [Mvar]	[MW]/ [Mvar]	[MW]/ [Mvar]	[MW]/ [Mvar]	[MW]/ [Mvar]	[MW]/ [Mvar]	[MW]/ [Mvar]
\Andry Yuliansyah\skripsi\Network Model\Network Data\singlelinediagram								
13.92	0.00	20.71	0.00	7.00	0.00	0.21	0.21	0.00
9.76	0.00	12.83	0.00	3.86	0.00	0.79	0.79	0.00
Total:								
13.92	0.00	20.71	0.00	7.00		0.21	0.21	0.00
9.76	0.00	12.83	0.00	3.86		0.79	0.79	0.00